

October 28, 2021

NJSEA Lyndhurst Coating of Support Piles

Lyndhurst, New Jersey

Bid Due Date: November 12, 2021 @ 12:00PM

ADDENDUM #1

- A. Bid submission due date will be moved to Friday, November 12th, 2021. Thursday, November 11th, 2021 is a scheduled holiday and NJSEA offices will be closed.
- B. As per Specification Section 02000-27 15.1, Expose all "A" pilings to a depth of twenty-four (24) inches below the soil surface. Expose all "B" pilings down to elevation -2.0. The NJSEA will lower the mean low tide a minimum of 24 inches to expose the pilings for the necessary work.

Include the acknowledgment of this addendum in your proposal submission.

Company Name (Print) Date

Receipt of Addendum #1: _____ (Signature)

End of Addendum #1