

July 27, 2022

**Meadowlands Arena Motor Control Center**

East Rutherford, New Jersey

**Bid Due Date:** August 11<sup>th</sup>, 2022 @ 12:00PM

**ADDENDUM #1**

- A. The Bid walk summary is incorporated with the changes below and should be included in the bid pricing. Changes included in this bid walk:
- i. **Add Alternate #1 GFI Outlets:** Add Alternate is to install three (3) 20-amp, direct line GFI outlets. Locations of these outlets include a new installation on the new motor control center as well as replacements of the two shown in the attached pictures. These three outlets must operate on independent circuits. Pricing sheet is attached. Please include this pricing sheet with your bid submission.
  - ii. **Add Alternate #2 Replacement of Feed from Arena:** In the event that testing by High Energy Electric indicates that the feed from the Arena is compromised, it will require replacement. Add alternate is to replace the approx. 150' electrical line which runs underground from Electrical Substation #4 into the bottom of the existing motor control center. Pricing sheet is attached. Please include this pricing sheet with your bid submission.
  - iii. The three cooling towers that will remain in operation through temporary power are towers 2, 3, and 4 as shown during the bid walk. Cell 2 to be on smaller disconnect (smaller power source). Cells 3 and 4 to share the larger disconnect.
  - iv. Item 27.2 in section 02100 "Technical Specifications – Electrical" states that "Core drilling is permitted during overtime hours only." This is not the case, as the building in consideration is not an occupied building. Therefore, all drilling can take place during normal working hours.

**Attachments:**

Pricing Sheet for Addendum #1 (GFI Outlets) and Addendum #2 (Replacement of Feed from Arena)

Existing Electrical Outlet Images

Include the acknowledgment of this addendum in your proposal submission.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Name (Print)

\_\_\_\_\_  
Date

Receipt of Addendum #1: \_\_\_\_\_ (Signature)

**End of Addendum #1**

**SCHEDULE OF BID PRICES - ADD ALTERNATE #1**

**GFI Outlets:**

I (we) herein propose the following price for the work described in MEADOWLANDS ARENA COOLING TOWER MOTOR CONTROL CENTER REPLACEMENT ADD ALTERNATE #1 - GFI OUTLETS:

( \$ \_\_\_\_\_ )  
Lump Sum - *in words*

( \$ \_\_\_\_\_ )  
Lump Sum - *in figures*

Work only to be done at discretion of the NJSEA.

\_\_\_\_\_  
*Contractor Signature*

\_\_\_\_\_  
*Date*

**SCHEDULE OF BID PRICES - ADD ALTERNATE #2**

**Replacement of Feed from Arena:**

I (we) herein propose the following price for the work described in MEADOWLANDS ARENA COOLING TOWER MOTOR CONTROL CENTER REPLACEMENT ADD ALTERNATE #2 - REPLACEMENT OF FEED FROM ARENA:

( \$ \_\_\_\_\_ )  
Lump Sum - *in words*

( \$ \_\_\_\_\_ )  
Lump Sum - *in figures*

Work only to be done at discretion of the NJSEA.

\_\_\_\_\_  
*Contractor Signature*

\_\_\_\_\_  
*Date*





TO BE REPLACED  
W/ NEW GFI  
OUTLET

2022/07/27 11:02





TO BE REPLACED  
W/ NEW GFI  
OUTLET

2022/07/27 11:02