

December 16th, 2022

NJSEA NJ#4900-002 Bridge Deck Repairs

East Rutherford, New Jersey

Proposal Due Date: January 10th, 2023 @ 12:00PM

ADDENDUM #1

RFI Questions

1. **Question: When must all work be completed by?**

Response: All work must be completed by late March or early April at the latest to be ready for Stadium Event traffic.

2. **Question: Which lanes require work?**

Response: All lanes on either side of the bridge must be repaired if necessary. Please note one lane on either side must remain open for traffic during the entire duration of work.

3. **Question: For Items 8, 9 & 10, *Elastomeric Joint Assembly Items*, Can the Quantities of work to be performed be verified for each item?**

Response: Item 8 – 1 ¾" BY 2" PREFORMED ELASTOMERIC JOINT ASSEMBLY entirely replaces the existing elastomeric joint assemblies between each approach slab the abutment header, at each approach. The as-built length of the joint, from inside face of parapet to inside face of parapet, is 100 linear feet.

Item 9 – 2 1/2" BY 2 3/4" PREFORMED ELASTOMERIC JOINT ASSEMBLY entirely replaces the existing elastomeric joint assembly at them midspan transverse deck joint. The as-built length of the joint, from inside face of parapet to inside face of parapet, is 100 linear feet.

Item 10 – 4" BY 4 3/4" PREFORMED ELASTOMERIC JOINT ASSEMBLY entirely replaces the existing elastomeric joint assemblies between the bridge deck and the abutment header, at each end of the bridge. The as-built length of the joint, from inside face of parapet to inside face of parapet, is 100 linear feet.

4. **Question: For Item 7, *Deck Joint Repair*, will a new structural steel armored joint be required and should be included for this item?**

Response: A new structural steel armored joint will be required, as directed by the RE, in accordance with subpart 506.03.06 of the Special Provisions, and shall be included in the linear foot unit price bid for the item STEEL DECK JOINT REPAIR.

5. **Question: For Items 8, 9 & 10, *Elastomeric Joint Assembly Items*, in all cases does a new block out have to be constructed and are both sides of the block out to be paid for in the per LF Unit Price?**

Response: A new block out shall be constructed as directed by the RE. The limits of removal and block out reconstruction shall be as directed by the RE and in accordance with the NJDOT Bridge Deck Rehabilitation Deck Joint Repair details (please see sheets 9 and 10). All costs thereof shall be included in the linear foot price bid for the various joint items included in the proposal.

Replacement of any damaged steel deck joint armoring as directed by the RE shall be paid for under the item STEEL DECK JOINT REPAIR.

6. **Question: Can the Bid due date be extended by several days, most vendor services will be closed due to the *Seasonal Holiday Period* and will reopen for normal business on January 3, 2023?**
Response: The bid due date will be extended to January 10, 2023 at 12:00PM.

Bid Walk Notes

Below are notes covered during the bid walk:

1. The bid sheet and advertisement included an error in the bid due dates- The correct due date is January 10th, 2023 and an updated version of these pages have been attached for your submission. ****NOTE: You *MUST* submit the updated set of pages in the Specifications with the correct date, or your submission will be invalid. ****
2. The following dates must be adhered to be considered for award:
 - a. December 16th, 2022 at 3:00M – All questions and concerns must be submitted
 - b. January 10th, 2023 at 12:00PM – All bids must be delivered to One Dekorte Park Plaza Lyndhurst, NJ, 07071 (hand delivered or mailed)
3. As discussed at the bid walk, existing potholes will be filled with asphalt mix to make them safe throughout the winter. Please plan on removing the mix as part of your repairs during your work.
4. An allowance for the South Bridge repairs may be added to the project. NJSEA to advise with more information.
5. In Section 00010 “Advertisement for Bids,” the contract time states 120 days from the start date given. For clarification, the *work itself* must be completed within 30 days of the start of work, as stated in the “Scope of work.”
6. The schedule of bid prices has been updated to reflect changes in estimated quantities. On the attached document, the page describes the small changes made to the quantities in the schedule of bid prices that we reissued in the updated specifications. ****NOTE: You *MUST* submit the updated schedule of bid with the corrected quantities, or your submission will be invalid. ****
7. For clarification and ease of reference, a list is shown below of anticipated submittals but is not intended to be all inclusive. The respective subsection of the NJDOT Standard Specifications or Special Provisions is included for reference.
The necessary submittals may not be explicitly listed in Table 105.05-1 of either document. Please note that the NJDOT Standard Specifications are incorporated by reference into the project’s Special Provisions. In general, the Contractor must submit methods of construction, material designations, design calculations, catalogue cuts, illustrations, schedules, performance charts, brochures, and other information necessary to construct the work as specified in the Contract and to perform the work to the satisfaction of the NJSEA.

Submittal	Standard Specifications Subsection	Special Provisions Subsection
Health & Safety Program	108.05.02	
Material Certifications & Questionnaires	106.04	
Bar Chart Progress Schedule	153.03.03	
Traffic Control Coordinator Qualifications		159.03.01

Demolition plan		201.03.02
Temporary Shielding	201.03.09	
Shoring and/or Falsework Scheme		204.03
Joint Assemblies		507.03.01.A
Stay-in-place (SIP) Forms		507.03.02.A(1)
Deck Joint Installation Procedure(s)	551.03.06	
Concrete Mix Design	551.02.01	
Quick-Setting Patch Materials	551.02.01	
Reinforcement Steel	551.02.01	
Pneumatic Hammer Tech. Data Sheets	551.02.02	
Traffic Stripes	610.02.01	
Traffic Striping Plan	610.03.01.A	

Attachments

1. Updated Bridge Deck Repair Pages- 12.15.22
2. Schedule of Bid Prices- Updated 12.14.22

Include the acknowledgment of this addendum in your proposal submission.

Company _____ Name (Print) _____ Date _____

Receipt of Addendum #1: _____ (Signature)

End of Addendum #1

**NEW JERSEY SPORTS & EXPOSITION AUTHORITY
PROJECT CN-277 NJ#4900-002 BRIDGE DECK REPAIRS
NORTH CONNECTOR ROAD AND RAMP "F" OVER NJ 120
IN THE BOROUGH OF EAST RUTHERFORD
BERGEN COUNTY, NEW JERSEY**

ADDENDUM NO. 1

DATE: DECEMBER 14, 2022

Page 1 of 5

NOTICE

This addendum does not alter the bid date.

THE FOLLOWING CHANGES ARE MADE TO THE PROPOSAL:

ITEM NO.	ITEM	REMARKS
11 (551006M)	CONCRETE DECK REPAIR, TYPE B	Quantity is DECREASED from 9300 SF to 2100 SF
12 (551009M)	CONCRETE DECK REPAIR, TYPE C (IF & WHERE DIRECTED)	Quantity is DECREASED from 500 SF to 250 SF

THE SCHEDULE OF BID PRICES IS **REISSUED**:

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

SCHEDULE OF BID PRICES

NJSEA NJ#4900-002 BRIDGE DECK REPAIRS

ITEM NO.	ESTIMATED QUANTITIES	ITEM	UNIT PRICE	AMOUNT
1.	LUMP SUM	MOBILIZATION	\$_____	\$_____
2.	LUMP SUM	MAINTENANCE AND PROTECTION OF TRAFFIC	\$_____	\$_____
3.	1 DOL	CONSTRUCTION LAYOUT	\$_____	\$_____
4.	LUMP SUM	CONCRETE WASHOUT SYSTEM	\$_____	\$_____
5.	1 UNIT	OIL ONLY EMERGENCY SPILL KIT, TYPE 1	\$_____	\$_____
6.	LUMP SUM	CLEARING SITE	\$_____	\$_____
7.	40 LF	STEEL DECK JOINT REPAIR	\$_____	\$_____
8.	200 LF	1 3/4" BY 2" PREFORMED ELASTOMERIC JOINT ASSEMBLY	\$_____	\$_____
9.	100 LF	2 1/2" BY 2 3/4" PREFORMED ELASTOMERIC JOINT ASSEMBLY	\$_____	\$_____
10.	200 LF	4" BY 4 3/4" PREFORMED ELASTOMERIC JOINT ASSEMBLY	\$_____	\$_____
11.	2100 SF	CONCRETE DECK REPAIR, TYPE B	\$_____	\$_____
12.	250 SF	CONCRETE DECK REPAIR, TYPE C (IF & WHERE DIRECTED)	\$_____	\$_____
13.	65 LF	BRIDGE HEADER REPAIR	\$_____	\$_____

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

14.	187 LF	DECK JOINT RESEAL (RUBBER ASPHALT)	\$_____	\$_____
15.	1312 LF	TRAFFIC STRIPES, 4"	\$_____	\$_____

I (we) her in propose to furnish and install all work associated with the work described in these Bid Documents for the **NJ#4900-002 BRIDGE DECK REPAIRS**

(\$ _____)
Lump Sum - *in words*

(\$ _____)
Lump Sum - *in figures*

I, or We, hereby commit to complete this **Project within:**

Number of Calendar Days to Complete

Contractor Signature

If this Bid shall be accepted by the NJSEA, and the undersigned shall fail to contract as aforesaid, the NJSEA shall be entitled to recover from the Bidder those moneys as specified in Article 7.0 of the **INSTRUCTIONS TO BIDDERS**.

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

If a Corporation:

Name of Company _____

Business Address _____

Business Telephone Number _____

Incorporated under the laws of the State of _____

Signature and Title of Bidder _____

(Signature)

(Typed Name)

(Typed Title)

Name of President _____

Name of Secretary _____

Name of Treasurer _____

Date _____

(Affix Corporate Seal Here)

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

If a Partnership, Individual, or Non-Incorporated Organization:

Name of Company _____

Business Address _____

Business Telephone Number _____

Signature and Title of Bidder _____
(Signature)

(Typed Name)

(Typed Title)

Dated _____

Typed Names and Addresses of Company Members:

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

(Use Additional Sheets if Necessary)

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

SECTION 00010

ADVERTISEMENT FOR BIDS

Notice is hereby given that sealed bids will be received by the New Jersey Sports and Exposition Authority (NJSEA), One DeKorte Park Plaza Lyndhurst, NJ, 07071 for the following:

BID CONTRACT:

NJ#4900-002 BRIDGE DECK REPAIRS

THE WORK to be performed under this Contract will consist of deck repairs of the bridge over State Route 120, NJ#4900-002.

BIDS will be received at the above address until **12:00 PM** prevailing time, on **January 10th, 2023**. At the termination of the time for receipt of bids, the bids received will be opened. Bids will **not** be accepted after **12:00 PM** on that day. Due to COVID, bids will not be opened in a public forum.

CONTRACT DOCUMENTS (specifications and plans) will be available for review at the NJSEA website beginning on **November 29th, 2022, after 2:00 PM**. Copies of the specifications and the plan set may be downloaded from the NJSEA website at www.NJSEA.com.

A mandatory PRE-BID MEETING will be held on **December 6th, 2022 at 10:00 AM** at the NJSEA Meadowlands Arena Employee Entrance (North entrance between Gates B & C across from Lot 27). The pre-bid meeting will consist of a short meeting at the NJSEA offices, followed by a project site visit. All firms who attend the bid walk must submit all questions and concerns by **December 16th, 2022 at 3:00 PM**.

THE CONTRACT TIME is 120 consecutive calendar days from the start date given in the Notice-To-Proceed.

A BID DEPOSIT in the amount of five percent of the bid, but not exceeding \$20,000.00, must accompany the Bid. This in the form may be of a bid bond or certified check.

The Contract Documents contain specific requirements for submission of a bid. In conformance with Public Law 1977, Chapter 33, if the bidder is a corporation or partnership, it shall submit with the bid a statement setting forth the names and addresses of all stockholders/partners who have a ten percent or greater interest in the firm.

The attention of all bidders is particularly called to the New Jersey State requirements regarding the conditions of employment to be observed. All bidders are required to comply with the requirements of N.J.S.A. 10:5-31 et seq. and N.J.A.C. 17:27, regarding Affirmative Action.

New Jersey Sports & Exposition Authority
Project CN-277 NJ#4900-002 Bridge Deck Repairs

SECTION 00300

BID SHEET: PROJECT CN-277

TO: The New Jersey Sports and Exposition Authority (NJSEA)

RE: NJSEA NJ#4900-002 BRIDGE DECK REPAIRS

This bid will not be accepted after 12:00 PM prevailing local time on, January 10th, 2023. There will not be a public bid opening due to COVID. The bidder agrees that this bid will not be withdrawn for a period of 60 calendar days after the closing time for receipt of bids.

(Name of Firm Submitting Bid)

The undersigned hereby acknowledges receipt of the following addenda:

ADDENDUM NO.

DATE

The following documents are included with this bid:

1. Bid Security (including Power of Attorney if bid security is in the form of a bond)
2. Consent of Surety
3. Bidder's Experience Affidavit
4. Bidder's Disclosure Form
5. Bidder's Affidavit of Authorization
6. Moral Integrity Affidavit
7. Non-Collusion Affidavit
8. Subcontractor Use Form
9. Proof of Registration in accordance with the Public Works Contractor Registration Act (For Contractor and all listed subcontractors)
10. Notice to All Bidders of Set-Off for State Tax
11. Corporate Resolution Form
12. Two-Year Chapter 51/Executive Order 117 Vendor Certification And Disclosure Of Political Contributions
13. Iran Certification Form
14. Certification Of Non-Debarment For Federal Government Contracts [N.J.S.A. 52:32-44.1 (P.L. 2019, C.406)]