
300 Kimball Drive Parsippany, NJ 07054 T: 973.560.4900 F: 973.560.4901

To: John Duffy - NJSEA

From: Vijay Patel, Miroslaw Baran

Info: Peter Urgola, Claudia Locricchio, Madison Kidd - NJSEA

Date: November 14, 2022

Re: Limited Asbestos Containing Materials Sampling
Meadowland Arena – Lower Roof
Meadowlands Sports Complex
East Rutherford, NJ 07073
Langan Project No.: 100952903

This report by Langan Engineering & Environmental Services, Inc. (Langan) summarizes asbestos containing materials (ACM) findings associated with the Arena building lower roofs, Meadowlands Sports Complex, East Rutherford, NJ 07073. Langan's scope for the project was limited to the sampling of suspect roofing materials associated with the Lower Roofs of the subject Arena building. Roof cores and patching was completed by GAF representatives.

SUMMARY OF OBSERVATIONS AND FINDINGS

Twenty three (23) representative bulk samples (with sub-layers) of suspect ACM were collected during the November 3, 2022 site visit. Materials determined to be ACM through testing, are summarized below.

Material	Location	Survey Results
Roof flashing along roof perimeter, vents, ducts, air handling unit supports, conduits and any other roof openings	Lower Roofs	ACM

Table 1 in Attachment A presents a summary of suspect materials observed and sampled during our site visit.

RECOMMENDATIONS

We understand that the project involves replacement of roofing materials. All identified ACM which would be impacted by planned project activities shall be properly abated in accordance with Federal, State, and Local regulations. Disposal of this waste shall be in accordance with New Jersey Department of Environmental Protection (NJDEP) requirements.

Enclosures:

Attachment A: Limited Asbestos Assessment Findings

Attachment B: Asbestos Laboratory Analytical Results and chain-of-Custody Documentation

Attachment A

Limited Asbestos Assessment Findings

Table 1 - SUMMARY OF ASBESTOS SURVEY FINDINGS
FORMER CONTINENTAL ARENA East Rutherford, NJ 07073

Material	Sample ID	Material Locations	Survey Results		Notes/Comments
ACM/ASSUMED ACM FINDINGS					
Roof flashing	RF-1	Flashing areas along roof perimeter and roof penetrations with vents, ducts and conduits – Roof Section with Gravels; Roof penetrations with vents, ducts, conduits and air handling units support bases – Plane Roof Sections	ACM	CHRY 2.0%	---
NON-ACM FINDINGS					
Built-up roofing membrane	RM-1	Plane Roof	Non-ACM	ND	Top layer
Roof insulation	RIN-1		Non-ACM	ND	Middle layer
Roof felt paper on concrete deck	RFT-1		Non-ACM	ND	Bottom layer
Built-up roofing membrane	RM-2	Roof with Gravel	Non-ACM	ND	Top layer
Roof insulation	RIN-2		Non-ACM	ND	Middle layer
Tar between layers of insulation	RT-1		Non-ACM	ND	Middle layer
Roof insulation	RIN-2		Non-ACM	ND	Middle layer
Tar on concrete deck	BT-1		Non-ACM	ND	Bottom layer
Roof membrane patch	RPT-1	Roof with Gravel	Non-ACM	ND	---
White mastic on duct insulation	DM-1	Plane Roof	Non-ACM	ND	---

- 1 A material with asbestos content greater than one percent (>1.0%) is considered as an asbestos-containing material (ACM). Concentrations in weight percent.
- 2 ND = "None Detected" – Asbestos not detected in sampled material.
- 3 CHRY = Chrysotile Asbestos

DRAFT MEMO

Meadowland Arena – Lower Roof
Meadowlands Sports Complex
East Rutherford, NJ 07073
Langan Project No.: 100952903
November 14, 2022 - Page 3 of 8

Attachment B

Asbestos Laboratory Analytical Results and chain-of-Custody Documentation

**AmeriSci New York**

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Langan Engineering & Environmental Services
Attn: Vijay Patel
300 Kimball Drive
4th Floor
Parsippany, NJ 07054

Date Received 11/05/22
Date Examined 11/06/22

AmeriSci Job # 222111434
P.O. #
Page 1 **of** 5

RE: 100952903; Former Continental Arena - Roof Testing; Former Continental Arena: East Rutherford, NJ 07073

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
RM-1-A RM1	222111434-01 Location: Plane Roof - Built-Up Roofing Membrane (Top)	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%			
RIN-1-A RIN1	222111434-02 Location: Plane Roof - Roof Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 60%, Non-fibrous 40%			
RM-1-B RM1	222111434-03 Location: Plane Roof - Built-Up Roofing Membrane (Top)	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%			
RIN-1-B RIN1	222111434-04 Location: Plane Roof - Roof Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 60%, Non-fibrous 40%			
RM-2-A RM2	222111434-05 Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%			

PLM Bulk Asbestos Report

100952903; Former Continental Arena - Roof Testing; Former
Continental Arena: East Rutherford, NJ 07073

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
RIN-2-A RIN2 Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 60%, Non-fibrous 40%	222111434-06 Location: Roof W/ Gravel - Roof Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
RM-2-B RM2 Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%	222111434-07 Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
RIN-2-B RIN2 Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 60%, Non-fibrous 40%	222111434-08 Location: Roof W/ Gravel - Roof Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
RM-2-C RM2 Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%	222111434-09 Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
RIN-2-C RIN2 Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 60%, Non-fibrous 40%	222111434-10 Location: Roof W/ Gravel - Roof Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
RFT-1-A RFT1 Analyst Description: Dark Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 75%, Fibrous glass 5%, Non-fibrous 20%	222111434-11 Location: Plane Roof - Roof Felt On Concrete Deck	No	NAD (by CVES) by Jared C. Clarke on 11/06/22

PLM Bulk Asbestos Report

100952903; Former Continental Arena - Roof Testing; Former
Continental Arena: East Rutherford, NJ 07073

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
RFT-1-B RFT1	222111434-12 Location: Plane Roof - Roof Felt On Concrete Deck	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Dark Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 75%, Fibrous glass 5%, Non-fibrous 20%			
RT-1-A RT1	222111434-13 Location: Roof W/ Gravel - Tar Between Layers Of Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100%			
RT-1-B RT1	222111434-14 Location: Roof W/ Gravel - Tar Between Layers Of Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100%			
BT-1-A BT1	222111434-15 Location: Roof W/ Gravel - Tar On Concrete Deck	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100%			
BT-1-B BT1	222111434-16 Location: Roof W/ Gravel - Tar On Concrete Deck	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100%			
RPT-1-A RPT1	222111434-17 Location: Roof W/ Gravel - Roof Membrane Patch	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%			

PLM Bulk Asbestos Report

100952903; Former Continental Arena - Roof Testing; Former
Continental Arena: East Rutherford, NJ 07073

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
RPT-1-B RPT1	222111434-18 Location: Roof W/ Gravel - Roof Membrane Patch	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 15%, Fibrous glass 5%, Non-fibrous 80%			
DM-1-A DM1	222111434-19 Location: Plane Roof - White Mastic On Duct Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Silver/White, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 15%, Non-fibrous 85%			
DM-1-B DM1	222111434-20 Location: Plane Roof - White Mastic On Duct Insulation	No	NAD (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Silver/White, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 15%, Non-fibrous 85%			
RF-1-A RF1	222111434-21 Location: Roof W/ Gravel - Roof Flashing	Yes	2% (by CVES) by Jared C. Clarke on 11/06/22
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 2.0 % Other Material: Cellulose 10%, Non-fibrous 88%			
RF-1-B RF1	222111434-22 Location: Roof W/ Gravel - Roof Flashing		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			
RF-1-C RF1	222111434-23 Location: Plane Roof - Roof Flashing		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			

Client Name: Langan Engineering & Environmental Services

PLM Bulk Asbestos Report

100952903; Former Continental Arena - Roof Testing; Former
Continental Arena: East Rutherford, NJ 07073

Reporting Notes:

Analyzed by: Jared C. Clarke
Date: 11/6/2022



Reviewed by: Feyza Gungor



*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop, (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; PLM Bulk Asbestos Analysis using Motic, Model BA310 Pol Scope, Microscope, Serial #: 1190000326, by Appd E to Subpt E, 40 CFR 763 quantified by either CVES or 400 pt ct as noted for each analysis (NVLAP 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite, or ELAP 198.6 for NOB samples, or EPA 400 pt ct by EPA 600-M4-82-020 (NY ELAP Lab 11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. RI Cert AAL-094, CT Cert PH-0186, Mass Cert AA000054, NJ Lab ID #NY031.

_____END OF REPORT_____

Client Name: Langan Engineering & Environmental Services

Table I
Summary of Bulk Asbestos Analysis Results

100952903; Former Continental Arena - Roof Testing; Former Continental Arena: East Rutherford, NJ 07073

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	RM-1-A	RM1	0.268	60.8	29.7	9.4	NAD	NAD
	Location: Plane Roof - Built-Up Roofing Membrane (Top)							
02	RIN-1-A	RIN1	----	----	----	----	NAD	NA
	Location: Plane Roof - Roof Insulation							
03	RM-1-B	RM1	0.326	60.7	26.9	12.4	NAD	NAD
	Location: Plane Roof - Built-Up Roofing Membrane (Top)							
04	RIN-1-B	RIN1	----	----	----	----	NAD	NA
	Location: Plane Roof - Roof Insulation							
05	RM-2-A	RM2	0.506	64.6	4.2	31.2	NAD	NAD
	Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)							
06	RIN-2-A	RIN2	----	----	----	----	NAD	NA
	Location: Roof W/ Gravel - Roof Insulation							
07	RM-2-B	RM2	1.061	68.3	3.7	28.0	NAD	NAD
	Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)							
08	RIN-2-B	RIN2	----	----	----	----	NAD	NA
	Location: Roof W/ Gravel - Roof Insulation							
09	RM-2-C	RM2	0.582	88.9	2.5	8.6	NAD	NAD
	Location: Roof W/ Gravel - Built-Up Roofing Membrane (Top)							
10	RIN-2-C	RIN2	----	----	----	----	NAD	NA
	Location: Roof W/ Gravel - Roof Insulation							
11	RFT-1-A	RFT1	0.103	90.0	5.9	4.1	NAD	NAD
	Location: Plane Roof - Roof Felt On Concrete Deck							
12	RFT-1-B	RFT1	0.132	90.9	6.4	2.7	NAD	NAD
	Location: Plane Roof - Roof Felt On Concrete Deck							
13	RT-1-A	RT1	0.180	72.9	6.3	20.7	NAD	NAD
	Location: Roof W/ Gravel - Tar Between Layers Of Insulation							
14	RT-1-B	RT1	0.149	84.5	5.9	9.6	NAD	NAD
	Location: Roof W/ Gravel - Tar Between Layers Of Insulation							
15	BT-1-A	BT1	0.190	85.3	4.1	10.6	NAD	NAD
	Location: Roof W/ Gravel - Tar On Concrete Deck							
16	BT-1-B	BT1	0.126	90.5	6.3	3.3	NAD	NAD
	Location: Roof W/ Gravel - Tar On Concrete Deck							

Client Name: Langan Engineering & Environmental Services

Table I
Summary of Bulk Asbestos Analysis Results

100952903; Former Continental Arena - Roof Testing; Former Continental Arena: East Rutherford, NJ 07073

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
17	RPT-1-A	RPT1	0.267	89.3	2.9	7.8	NAD	NAD
Location: Roof W/ Gravel - Roof Membrane Patch								
18	RPT-1-B	RPT1	0.347	62.3	22.8	14.9	NAD	NAD
Location: Roof W/ Gravel - Roof Membrane Patch								
19	DM-1-A	DM1	0.263	56.0	26.3	17.7	NAD	NAD
Location: Plane Roof - White Mastic On Duct Insulation								
20	DM-1-B	DM1	0.169	54.4	27.3	18.3	NAD	NAD
Location: Plane Roof - White Mastic On Duct Insulation								
21	RF-1-A	RF1	----	----	----	----	Chrysotile 2.0	NA
Location: Roof W/ Gravel - Roof Flashing								
22	RF-1-B	RF1	----	----	----	----	NA/PS	NA
Location: Roof W/ Gravel - Roof Flashing								
23	RF-1-C	RF1	----	----	----	----	NA/PS	NA
Location: Plane Roof - Roof Flashing								

Analyzed by: Feyza Gungor

Date: 11/7/2022



Reviewed by: Feyza Gungor



**Quantitative Analysis (Semi/Full); Bulk Asbestos Analysis - PLM by Appd E to Subpt E, 40 CFR 763 or NYSDOH ELAP 198.1 for New York friable samples or NYSDOH ELAP 198.6 for New York NOB samples; TEM (Semi/Full) by EPA 600/R-93/116 (or NYSDOH ELAP 198.4; for New York samples). Analysis using Hitachi, Model H600-Noran 7 System, Microscope, Serial #: 542-26-10. NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "NVA = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses): NVLAP (PLM) 200546-0, NYSDOH ELAP Lab 11480, NJ Lab ID #NY031.

Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogenous materials).


LANGAN

300 Kimball Drive
Parsippany, NJ 07054
Phone: 973-560-4900
Fax: 973-560-4901

CHAIN OF CUSTODY RECORD / ANALYSIS REQUEST

1 OF 3

#222111434

Project Name: FORMER CONTINENTAL ARENA - ROOF TESTING				Analysis Requested for Asbestos			Analysis Requested for Lead		Analysis Requested for PCB	Results
Address: FORMER CONTINENTAL ARENA, East Rutherford, NJ 07073		Auth. By: Vijay Patel		PLM	PLM-NOB	TEM	AAS	TCLP	EPA Method 8082	
Langan Job No.: 100952903		Phone No: 973.560.4983								
Sampled By/License #: MIROSLAW BARAN		Sampling Date: 11/3/2022								
Sample #	Sample ID	Description of Sample	Sample Location							
1	RM-1-A	Built-up roofing membrane - top	Plane Roof	X		X				
2	RIN-1-A	Roof insulation	Plane Roof	X						
3	RM-1-B	Built-up roofing membrane - top	Plane Roof	X		X				
4	RIN-1-B	Roof insulation	Plane Roof	X						
5	RM-2-A	Built-up roofing membrane - top	Roof with Gravel	X		X				
6	RIN-2-A	Roof insulation	Roof with Gravel	X						
7	RM-2-B	Built-up roofing membrane - top	Roof with Gravel	X		X				
8	RIN-2-B	Roof insulation	Roof with Gravel	X						
9	RM-2-C	Built-up roofing membrane - top	Roof with Gravel	X		X				
10	RIN-2-C	Roof insulation	Roof with Gravel	X						
Total No. of Samples: 10				Turnaround Request:						
				RUSH	12 hours	24 hours	48 hours	72 hours	5 days	
							X			
Laboratory Instructions: Stop analysis @ 1st positive (>1% by weight) for each homogenous sample group. Please e-mail results to mbaran@langan.com and vpatel@langan.com . Please analyze all fireproofing, plaster and wall coating materials samples. Do not stop analysis @ 1st positive (>1% by weight).										
Relinquished By: MIROSLAW BARAN		Date: 11/4/2022	Time:	Received by: 		Date: 11/5/22	Time: 1105			
Company: LANGAN				Company: AmeriSCM						

Laboratory Name:

LANGAN

300 Kimball Drive
Parsippany, NJ 07054
Phone: 973-560-4900
Fax: 973-560-4901

CHAIN OF CUSTODY RECORD / ANALYSIS REQUEST

2 OF 3

#222111434

Project Name: FORMER CONTINENTAL ARENA - ROOF TESTING				Analysis Requested for Asbestos			Analysis Requested for Lead		Analysis Requested for PCB		Results
Address: FORMER CONTINENTAL ARENA, East Rutherford, NJ 07073		Auth. By: Vijay Patel		PLM	PLM-NOB	TEM	AAS	TCLP	EPA Method 8082		
Langan Job No.: 100952903		Phone No: 973.560.4983									
Sampled By/License #: MIROSLAW BARAN		Sampling Date: 11/3/2022									
Sample #	Sample ID	Description of Sample	Sample Location								
11	RFT-1-A	Roof felt on concrete deck	Plane Roof	X		X					
12	RFT-1-B	Roof felt on concrete deck	Plane Roof	X		X					
13	RT-1-A	Tar between layers of insulation	Roof with Gravel	X		X					
14	RT-1-B	Tar between layers of insulation	Roof with Gravel	X		X					
15	BT-1-A	Tar on concrete deck	Roof with Gravel	X		X					
16	BT-1-B	Tar on concrete deck	Roof with Gravel	X		X					
17	RPT-1-A	Roof membrane patch	Roof with Gravel	X		X					
18	RPT-1-B	Roof membrane patch	Roof with Gravel	X		X					
19	DM-1-A	White mastic on duct insulation	Plane Roof	X		X					
20	DM-1-B	White mastic on duct insulation	plane Roof	X		X					
Total No. of Samples: 10				Turnaround Request:		RUSH	12 hours	24 hours	48 hours	72 hours	5 days
Laboratory Instructions: Stop analysis @ 1st positive (>1% by weight) for each homogenous sample group. Please e-mail results to mbaran@langan.com and vpatel@langan.com. Please analyze all fireproofing, plaster and wall coating materials samples. Do not stop analysis @ 1st positive (>1% by weight).											
Relinquished By: MIROSLAW BARAN		Date: 11/4/2022	Time:	Received by:		Date: 11/5/22	Time: 1105				
Company: LANGAN				Company: AmeriSci NY							

Laboratory Name:

300 Kimball Drive
Parsippany, NJ 07054
Phone: 973-560-4900
Fax: 973-560-4901

3 OF 3

#222111434

[illegible]

Laboratory Name:

Big Apple Occupational Safety Inc

505 Eighth Avenue, #2305, New York, NY 10018
(212) 564-7656

This Is To Certify That

Miroslaw Baran

SS#: XXX-XX-XXXX

has successfully completed the New York State Department of Health approved course entitled
This course meets requirements of TSCA Title II

Asbestos Inspector Refresher - ONLINE WEBINAR

*(The official record of successful completion is the DOH 2832 Certificate of completion
New York State Department of Health Certificate of Asbestos Safety Training)*

Course Date: 05/05/2022

Expiration Date: 05/05/2023

Examination Date: 05/05/2022

Examination Grade: 96%

Certificate Number: 911121


Radha Reddy
Training Director